

Cu/PVC/PVC

BS 6004

Description :

Flat twin core cable, cores shall be laid parallel with copper conductor and PVC insulation.

Number of Cores & Cross Selection mm ²	Insulation Thickness mm	* Sheath Thickness		Cable Dimension		Total Weight Approx. kg/km
		e_1 mm	e_2 mm	Width Approx. mm	Thickness mm	
2 x 1 RE	0.6	1.0	0.9	6.5	4.3	56
2 x 1.5 RE	0.7	1.0	0.9	7.4	4.8	74
2 x 1.5 RM	0.7	1.0	0.9	7.7	5.0	77
2 x 2.5 RE	0.8	1.1	1.0	8.8	5.6	109
2 x 2.5 RM	0.8	1.1	1.0	9.2	5.8	114
2 x 4 RM	0.8	1.1	1.0	10.3	6.4	153
2 x 6 RM	0.8	1.2	1.1	11.6	7.1	208
2 x 10 RM	1.0	1.2	1.2	14.5	8.5	325
2 x 16 RM	1.0	1.3	1.3	16.0	9.3	448

1-Solid or Stranded Circular Conductor 2-PVC Insulation 3-PVC Sheathing.

* : e_1 , e_2 As FIG. 1




FIG. 1 - Cross-section of Cable